

14 PANEL SCREW 1 1/2"
 LONGER THAN PANEL THICKNESS
 SEE ENGINEERING DATA
 FOR SPACING REQUIREMENTS

INTERIOR DRYWALL

BEVELED 2x SEAT, 3"
 MINIMUM BEARING

CAULK-CONTINUOUS BEAD
 WOOD-TO-WOOD
 CONNECTIONS - TYP.

8d NAILS OR # 14 1 1/2"
 STAPLES- 6"O.C. - TYP.

FOAM SEALANT-CONTINUOUS
 BEAD - EPS-TO-WOOD

STRUCTURAL INSULATED PANEL
 INSTALLATION GUIDE

TITLE
 ROOF-TO-WALL CONNECTION
 PITCHED ROOF-BEVELED SEAT

PORTER
 STRUCTURAL INSULATED PANELS

W. H. PORTER, INC. 4240 N. 136th AVE HOLLAND, MI 49424 (616) 399-1963

11/02

38-301