

NOTE #1: THE OPENING SIZE, LOCATION, AND DESIGN ROOF LOADING MUST BE EVALUATED WHEN PENETRATING ROOF. MAXIMUM SIZE DETERMINED BY ENGINEERING REVIEW.

FILL WITH INSULATION RATED FOR APPLICATION

SEE NOTE # 1

2x LUMBER -
FRAME AS SHOWN
IN DRAWING
38-503

3" MINIMUM
CLEARANCE
PANEL-TO-VENT
OR AS REQUIRED
BY LOCAL CODE

VENT STACK

INTERIOR DRYWALL

NOTE # 3- PROTECT PENETRATION
AREA WITH TIGHT FITTING FLASHING
OVER VENT STACK

STRUCTURAL INSULATED PANEL
INSTALLATION GUIDE

TITLE FRAMED ROOF PENETRATION

PORTER
STRUCTURAL INSULATED PANELS

K. H. PORTER, INC. 4240 N. 130th AVE HOLLAND, MI 49424 (616) 399-1963

11/02

38-504